


Missouri
Department
of Transportation



Pete K. Rahn, Director

105 West Capitol Avenue
P.O. Box 270
Jefferson City, MO 65102
(573) 751-2551
Fax (573) 751-6555
www.modot.org

**ADDENDUM # 001
IFB 9 – 060927B**

September 21, 2006

To: Plans and Specifications Holders of List For:

Missouri Department of Transportation – **D5 - Ceiling Panel Insulation Installation, Various Locations.**

Scope of Work is hereby revised to include:

- ❖ Contractor shall install new R-19 insulation in sloped ceiling between existing rafters at the Jamestown location.
- ❖ Contractor shall remove existing vinyl faced pre-engineered type insulation installed with clips and replace with R19 at the Ashland, Drake, and Owensville building(s). If area is flat, a single layer of R-38 insulation will be acceptable.

Sheet 1 of 1 – Drawings:

- ❖ Currently Reads - *“Contractor to relocate all items that may be concealed above new drop ceiling. Items include but are not limited to unit heaters, electrical conduit, lighting fixtures, etc.”*
- ❖ Revised to Read – *“All electrical work will be handled by MoDOT personnel, including but not limited to, disconnecting any light fixtures or fans, temporarily moving during construction, and reinstalling.”*

Sincerely,

Sherry King
General Services - Facilities Management
573/522-5591
Sharon.King@modot.mo.gov

All other terms and conditions of IFB 9-060927B remain unchanged

END OF SECTION